

Declaration of Conformity

Preparation Date: 13th October 2015

We **Broyce Control Ltd**

Of Pool Street, Wolverhampton, West Midlands, England, WV2 4HN

Declare under our sole responsibility that the products:

LART, LEDO, LEIN, LESW and LMMT

to which this Declaration relates are in conformity with the following standards:

Product Standard

IEC 61812-1 / EN 61812-1

Emissions

EN 55011	Conductive Emissions – Class B	150kHz – 30MHz
EN 55011	Radiated Emissions – Class B	30MHz – 1GHz


Immunity (to EN 61812-1)

EN 61000-4-2	Electrostatic Contact Discharge test	±4kV (Contact) / ±8kV (Air)
EN 61000-4-3	Radio Frequency Immunity test	10V/m, 80MHz - 1GHz, 3V/m 1.4 - 2GHz, 1V/m 2GHz - 2.7GHz, 1kHz 80% AM
EN 61000-4-4	Fast Transients	±2kV (5kHz)
EN 61000-4-5	Surges	±1kV L>L
EN 61000-4-6	Conducted Radio Frequency Immunity	10Vrms, 150kHz – 80MHz, 1kHz, 80% AM
EN 61000-4-11	Voltage Dips and Interruptions ¹	Class 2

¹ Product Standard states if the functional interruption times are different from the required test level, this shall be acceptable and noted in the test report.

Signed by and on behalf of **Broyce Control Ltd**

Signature:
(David Gough)



Position: General Manager

Date: 13th October 2015